



INVITATION FOR BID STATEMENTS ADDENDUM
PURCHASING OFFICE
CITY OF AUSTIN, TEXAS

INVITATION FOR BID STATEMENTS: GGH0167 ADDENDUM NO. 4
DATE OF ADDENDUM: May 2, 2016

This addendum is to incorporate the following information:

- 1.0 Question: The basket tray attachment bolts are welded to the carrier chain on the subject water screen.
Does the basket tray attachment bolts welded to the carrier chain on the rebuilt water screen?
Answer: No, we will not have the bolts welded to the carrier chain.

All other terms and conditions remain the same.

BY THE SIGNATURES affixed below, this Addendum is hereby incorporated and made a part of the above-referenced Solicitation.

APPROVED BY:


Gabriela Harthcock, Buyer I
Purchasing Office, 512-322-6118

ACKNOWLEDGED BY:

SUPPLIER AUTHORIZED SIGNATURE DATE

RETURN ONE (1) COPY OF THIS ADDENDUM TO THE PURCHASING OFFICE, CITY OF AUSTIN, PRIOR TO RESPONSE CLOSING OR WITH YOUR SEALED RESPONSE. FAILURE TO DO SO MAY CONSTITUTE GROUNDS FOR REJECTION OF YOUR OFFER.