

The efficiency of a liquid-immersed distribution transformer manufactured on or after January 1, 2016, shall be no less than that required for their kVA rating in the table below. Liquid-immersed distribution transformers with kVA ratings not appearing in the table shall have their minimum efficiency level determined by linear interpolation of the kVA and efficiency values immediately above and below that kVA rating.

Table 5: Amended Energy Conservation Standards for Liquid-Immersed Distribution Transformers

Single phase		Three phase	
kVa	Efficiency (%)	kVa	Efficiency (%)
10	98.70	15	98.65
15	98.82	30	98.83
25	98.95	45	98.92
37.5	99.05	75	99.03
50	99.11	112.5	99.11
75	99.19	150	99.16
100	99.25	225	99.23
167	99.33	300	99.27
250	99.39	500	99.35
333	99.43	750	99.40
500	99.49	1000	99.43
667	99.52	1500	99.48
883	99.55	2000	99.51
		2500	99.53

Here's the website the references this information:

http://www1.eere.energy.gov/buildings/appliance_standards/product.aspx/productid/66#recentupdates