



ADDENDUM
PURCHASING OFFICE
CITY OF AUSTIN, TEXAS

Solicitation: IFB 1100 MEA1013

Addendum No: 3

Date of Addendum: 01/31/20

This addendum is to incorporate the following changes to the above referenced solicitation:

- I. **Q:** How is the current transformer currently mounted and what is the current transformer make and cat/style number?
- A: The current mounting is a 4-bracket mounting system. Currently use GE, Part number BO7-SD-13968AB bushing current transformers.
- II. ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME.

ACKNOWLEDGED BY:

Name

Authorized Signature

Date

RETURN ONE COPY OF THIS ADDENDUM TO THE PURCHASING OFFICE, CITY OF AUSTIN, WITH YOUR RESPONSE OR PRIOR TO THE SOLICITATION CLOSING DATE. FAILURE TO DO SO MAY CONSTITUTE GROUNDS FOR REJECTION.