

Specifications

IFB ISR0014
SEAL, TWO PART KIT A & B

1.0 Purpose

This specification establishes the minimum requirements for seal, two part kit A & B to be used by Austin Water (AW). The City Austin Water is required to use seal, two part kit A & B when necessary in their job function.

2.0 Material Requirements

AW has identified the product listed below as the model that meet their needs. Vendors may bid an equivalent as long as the bid equivalent meets or exceeds the manufacturer product specifications.

- Seal, two part Kit A & B – Miller Pipeline Corp Saf-T-Seal #2361 7600

2.1 Bidder may bid the brand specified or department approved equal. Bidder shall state in Section 0600 Bid Sheet if they are bidding an equivalent product. It is up to AW to determine product equivalency.

3.0 Product Requirements

- 3.1 Part A – chemical name Reaction product of Polypropylene glycol polymer with Toluene diisocyanate (TDI). Colorless to pale yellow viscous liquid
- 3.2 Part B – chemical name petroleum based tar blend;dark brown to black viscous liquid odor Hydrocarbon Aromatic.

4.0 Bidder Requirements: Samples, Inspection, and Test Requirements

- 4.1 Sample certification: With each sample, bidder shall submit written certification regarding manufacturer, material weight, and material ingredients. Once requested, a sample of seal, two part Kit A & B meeting the specifications as stated above shall be provided within 5 business days. **Do not send the sample with your bid.**
- 4.2 Bidder should provide documentation on test results with bid. Failure to provide test results may result in rejection of the bid. Test results shall include tests performed that determine product equivalency.
- 4.3 Detailed specifications including what materials the flares are comprised of should be provided with bid. Failure to provide detail specifications with bid may result in rejection of the bid.
- 4.5 If requested by the City, bidder shall submit a statement from the manufacturer that they are a currently approved distributor.
- 4.6 Seal, two part Kit A & B will be tested by AW for sealing manhole.

5.0 Order and Delivery Requirements

5.1 Delivery truck shall have a lift gate and pallet jack.

5.2 Orders shall be placed via electronic mail.

5.3 No minimum quantities placed on orders

5.4 Delivery shall be made within 30 business days after the order is placed (either verbally or in writing).

6.0 Required Bid Submittals

The following items should be submitted with the bid. Failure to submit the items or meet the results AW is requiring may result in rejection of the bid.

Items listed in section:

4.2- Test Results

4.3- Detail Specifications