



**ADDENDUM
PURCHASING OFFICE
CITY OF AUSTIN, TEXAS**

Solicitation: IFB 2200 OXV1043

Addendum No: 1

Date of Addendum: 8/13/2020

This addendum is to incorporate the following changes to the above referenced solicitation:

I. **Questions:** The following questions were posed by a Contractor in writing. Each question (Q) will be followed by its answer (A).

(Q) There is an overhead bridge crane available with operations personnel available to operate the crane.

(A) There is an overhead bridge crane available with operations personnel available to operate the crane. This project will be assisted by Operations staff present.

(Q) There are no obstructions to access for the motors.

(A) There are no obstructions to access for the motors. Scaffolding, scissor-lift, and/or ladders will be provided as necessary for access to the motor. Please refer to the attached pictures below for reference.

(Q) Is the upper bearing the main thrust bearing?

(A) It is believed a motor coupled to the vertical pump has the lower bearing as the main thrust bearing.

(Q) If the upper bearing is the main thrust bearing, the motor will need to be uncoupled in order to remove the bearing runner (quill) from the shaft to expose the standpipe for any type of repair work on it. Will uncoupling the motor be added to the work scope?

(A) The motor explicitly will not be uncoupled. The pump is a five (5) stage vertical turbine configuration with approximately a 325' (feet) shaft depth. Decoupling is an unnecessary extensive effort.

(Q) If uncoupling the motor is added, will the time allowed be increased?

(A) As the motor will not be uncoupled, this request is not applicable.

II. ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME.

APPROVED BY: **Osiris Valdez**
Osiris Valdez, Procurement Specialist II
Purchasing Office, (512) 974-2965

Digitally signed by Osiris Valdez
Date: 2020.08.13 13:10:42 -05'00'

8/13/2020
Date

ACKNOWLEDGED BY:

Name

Authorized Signature

Date

RETURN ONE COPY OF THIS ADDENDUM TO THE PURCHASING OFFICE, CITY OF AUSTIN, WITH YOUR RESPONSE OR PRIOR TO THE SOLICITATION CLOSING DATE. FAILURE TO DO SO MAY CONSTITUTE GROUNDS FOR REJECTION.









