

**Bidding Requirements, Contract Forms and Conditions of the Contract**  
**ADDENDUM**  
Section 00900

---

**ADDENDUM No.**   2  

Date   March 13, 2012  

City of Austin

Project Name   Dunlap 345 kV Substation  

C.I.P. No.   7477.01  

This Addendum forms a part of Contract and clarifies, corrects or modifies original Bid Documents, dated   February 20, 2012  . Acknowledge receipt of this addendum in space provided on bid form. Failure to do so may subject bidder to disqualification.

A. Project Manual Revisions:

None

B. Drawing Revisions:

Sheet 9 of 12

- Typical Yard Gravel Detail shows Final Grade above 4" crushed rock surface course. Final Grade should be below 4" crushed rock surface course.

This addendum consists of 1 page including this page.

  
\_\_\_\_\_

Approved by OWNER

  
\_\_\_\_\_

Approved by ENGINEER/ARCHITECT

**END**

