

Bidding Requirements, Contract Forms and Conditions of the Contract
ADDENDUM
Section 00900

ADDENDUM No. 3

Date March 15, 2012

City of Austin

Project Name Dunlap 345 kV Substation

C.I.P. No. 7477.01

This Addendum forms a part of Contract and clarifies, corrects or modifies original Bid Documents, dated February 20, 2012 . Acknowledge receipt of this addendum in space provided on bid form. Failure to do so may subject bidder to disqualification.

A. Project Manual Revisions:

Section 01010 Summary of Work

Section 1.07 should state 6 Ea. D/C Electric Panel (including breakers) provided by Owner instead of 4.

B. Drawing Revisions:

Sheet 7B-1164-B3

- Add Note 9 as follows:

"9. Spiral ties may be furnished in lieu of individual ties for pier reinforcing."

This addendum consists of 1 page including this page.



Approved by OWNER



Approved by ENGINEER/ARCHITECT

END

