



City of Austin

PUBLIC WORKS DEPARTMENT

Project Management Division

505 Barton Springs Road, Suite 900, Austin, TX 78704

Phone: (512) 974-7010; Fax: (512)-974-7222; email to: john.wepryk@austintexas.gov

Date: August 30, 2016

PROJECT: South Austin Regional Wastewater Treatment Plant – Thickener Improvements Project

CIP ID: 3333.016

IFB# 6100 CLMC558

SUBJECT: Answers to Bidders Questions as of the date of this letter, per 00100-IFB Article 1.(3)(C).

The following are answers to Bidders received on the above project. These answers do not modify the Contract. Any modifications to the Contract will be through Addenda

Q-12a: “11258 section 2.02.K.2 specifies that, ‘A single water panel shall be provided for each bioscrubber vessel.’ However, on the P&ID for the odor control systems (Drawing I-05 & I-06) it only shows one (1) water panel provided for each complete system consisting of two (2) bioscrubber vessels. Also within section 1.07.D the specs state, ‘Each bioscrubber system will consist of two vessels with durable inorganic media, two stacks, one fan, one water distribution system...’ Please clarify that only one (1) water panel per bioscrubber system is required.”

A-12b: Please refer to Addendum No. 3.

Q-12b: “11258-2.02.H.4 states ‘Instrumentation Specifications shall include but not be limited to the following:’ Note that the flow switch, differential pressure transmitters, temperature transmitters and pressure switches do NOT appear on the P&ID. We do not consider these necessary for the bioscrubber and assume that they are listed on an ‘as needed’ basis. Please confirm. Clarification could be provided in the form of changing – ‘Instrumentation Specifications shall include but not be limited to the following:’ to ‘Instrumentation Specifications, if required by the manufacturer, shall include but not be limited to the following:’”

A-12b: Please refer to Addendum No. 3.

Project Manager: Danny M. Hurtado, PE