



**ADDENDUM
CITY OF AUSTIN, TEXAS**

Solicitation: PAX0066REBID Addendum No: 1 Date of Addendum: 07/27/2015

This addendum is to incorporate the following changes, questions, and answers to the above referenced solicitation:

- 1.0 BID DUE PRIOR TO has been extended to: 08/04/2015, 2:00 pm, local time**
BID OPENING TIME AND DATE has been extended to: 08/04/2015, 2:15 pm, local time
- 2.0 (Q) Can you advise if there are local contractors bidding on the installation of the equipment? If so, can you provide a list of interest parties?**
(A) This information is not available at this time. The information can be provided after bid opening.
- 3.0 (Q) Did you have a pre-bid meeting for this solicitation? If so, can you provide an attendee roster?**
(A) No pre-bid meeting for this solicitation.
- 4.0 (Q) Your bid sheet has ten (10) 90-kVA converter and the specification calls for twelve (12). Can you confirm the quantity?**
(A) The quantity is ten (10).
- 5.0 (Q) Do you require output cables for the 400 HZ and 28 VDC? If so, please advise the required lengths.**
(A) 30'lf for each cable
- 6.0 ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME.**

APPROVED BY:

07/27/2015

Sai Xoomsai Purcell, Senior Buyer Specialist
Purchasing Office, 512-974-3058

ACKNOWLEDGED BY:

Name

Authorized Signature

Date

RETURN ONE COPY OF THIS ADDENDUM TO THE PURCHASING OFFICE, CITY OF AUSTIN, WITH YOUR RESPONSE OR PRIOR TO THE SOLICITATION CLOSING DATE. FAILURE TO DO SO MAY CONSTITUTE GROUNDS FOR REJECTION.