



**ADDENDUM
CITY OF AUSTIN, TEXAS**

Solicitation: PAX0066REBID Addendum No: 2 Date of Addendum: 07/29/2015

This addendum is to incorporate the following changes, questions, and answers to the above referenced solicitation:

- 1.0** (Q) Section 0500, item 2.1.4.2, external circuit breaker handles with lockout capability, would a magnetically controlled input safety contactor be acceptable as usually a input breaker is located downstream of the frequency converter in PBB applications which will have lockout tag out capability? The converter will be equipped with a door interlock that will open the contactor and remove the input power, as well as, trigger and audible alarm.
- (A) This lock out feature is acceptable.

2.0 ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME.

APPROVED BY:

07/29/2015

Sai Xoomsai Purcell, Senior Buyer Specialist
Purchasing Office, 512-974-3058

ACKNOWLEDGED BY:

Name

Authorized Signature

Date

RETURN ONE COPY OF THIS ADDENDUM TO THE PURCHASING OFFICE, CITY OF AUSTIN, WITH YOUR RESPONSE OR PRIOR TO THE SOLICIATION CLOSING DATE. FAILURE TO DO SO MAY CONSTITUTE GROUNDS FOR REJECTION.