



**ADDENDUM
CITY OF AUSTIN, TEXAS**

Solicitation: MEA0303RE-BID

Addendum No: 1

Date of Addendum: August 04, 2016

This addendum is to incorporate the following changes to the above referenced solicitation:

I QUESTION:

Q1: Austin Energy wants automated dampers on the discharge. Who is responsible for running the new conduit and cable?

A1: The Re-Bid Scope of Work has been revised. Please refer to Section 0500 Scope of Work (Technical Requirements) paragraph:

4.12 Each fan shall have actuated dampers at the inlets.

4.13 Each fan shall have a manual isolation valve and a check valve at the outlets.

II. ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME.

APPROVED BY: 
Maria Andrade, Buyer II
Purchasing Office, 512-972-9424

8/4/16
Date

ACKNOWLEDGED BY:

Name

Authorized Signature

Date

RETURN ONE COPY OF THIS ADDENDUM TO THE PURCHASING OFFICE, CITY OF AUSTIN, WITH YOUR RESPONSE OR PRIOR TO THE SOLICITATION CLOSING DATE. FAILURE TO DO SO MAY CONSTITUTE GROUNDS FOR REJECTION.