



ADDENDUM
PURCHASING OFFICE
CITY OF AUSTIN, TEXAS

REQUEST FOR PROPOSAL NO: **OPJ0114** ADDENDUM NO. **2**. DATE OF ADDENDUM: **MARCH 10, 2015**.

This addendum is to incorporate changes to the above referenced solicitation:

I. Change: This solicitation has been extended to 11:30 PM on Thursday, March 26, 2015. Proposals will be accepted until 11:30 PM on Thursday, March 26, 2015.

II. Change: The Compliance Plan will be due prior to Thursday, March 26, 2015, 4:00 PM.

III. A second Site Visit has been scheduled for Thursday, March 12, 2015 at 2:00 P.M. Location: Domain District Cooling Plant, 3120 Kramer Lane, Austin, TX 78758. The meeting place will be by the large roll-up door (it will be open). Purpose: To allow vendors to tour the work site again as was requested.

IV. The following are questions and answers regarding the above referenced solicitation.

1. **Question:** The chilled water system is called out to be insulated with elastomeric insulation but all the existing insulation on the chilled water system appears to be phenolic pipe insulation. Please confirm we are to provide what is called in the specification elastomeric insulation or match existing phenolic insulation.

Answer: Contractor to provide the specified elastomeric ArmaTuff Plus II system with 16 mil laminate or approved alternate.

2. **Question:** Is the contractor responsible for developing HMI graphics in the existing owner BAS? If so, please provide sample graphics or at least the number of graphics expected to be developed.

Answer: Austin Energy will be developing all of the HMI graphics. No contractor graphics required.

3. **Question:** Is the contractor responsible for configuring new alarms in the Owner's existing HMI?

Answer: Austin Energy will configure all the new alarms in the HMI. No contractor assistance required.

4. **Question:** What version of FactoryTalk View software does the Owner use?

Answer: 7.0.0.

5. **Question:** Are non marking tires required for the rental equipment?

Answer: Non marking tires are not required.

6. **Question:** Is there a restriction on the fuel type for the rental equipment?

Answer: No restrictions on fuel type.

7. **Question:** Does the new 30" x 30" duct require liner?

